

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



8(2) F O R M - (G)

Dated Guwahati the 22/8/2020

The Principal,
Kaliabor College of Education,
Kuwaritol, Nagaon,
Dist:- Nagaon, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE KALIABOR COLLEGE OF EDUCATION AT KUWARITOL, NAGAON, DIST:- NAGAON, ASSAM.

With reference to your completion report under No.

NIL

Dated 10.08.2020 I hereby certify that the building as per description below at Dag No. 426, 1641 Patta No. - Mouza Pubthoria, Langichok, (Place- Kuwaritol Nagaon) has been inspected in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention/ means of escape measures and is declared fit in respect fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of COLLEGE subject to condition mentioned below.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - 3600 ft²

2. Purpose of utilization: -

For College Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Manually Operated Electric Fire Alarm system
2. Fire Extinguishers

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

Dated Guwahati the _____

NO. F&ES/FPW/

Copy to:-

1. The Deputy Commissioner, Nagaon, Assam for information and necessary action.
2. The Commissioner/ Chairman, Nagaon Municipal Board, Assam for information and necessary action
3. The Station Officer, Kaliabor F&ES Station for information.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - 31.03.2021.
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2)
No. F&ES/FPW/
To,

F O R M - (G)

Dated Guwahati the _____

The Principal,
Kaliabor College of Education,
Kuwaritol, Nagaon,
Dist:- Nagaon, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN **THE KALIABOR COLLEGE OF EDUCATION AT KUWARITOL, NAGAON, DIST:- NAGAON, ASSAM.**

With reference to your completion report under No.

NIL

Dated **10.08.2020** I hereby certify that the building as per description below at
Dag No. **426, 1641** Patta No. - Mouza **Pubthoria, Langichok**,
(Place- **Kuwaritol Nagaon**) has been inspected in respect of implementation of Inbuilt Fire Fighting/
Fire Prevention/ means of escape measures and is declared fit in respect fire safety. The Fire &
Emergency Services, Assam has No objection in its occupation /utilization for the purpose of **COLLEGE**
subject to condition mentioned below.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - **3600 ft²**

2. Purpose of utilization: -
For College Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Manually Operated Electric Fire Alarm system
2. Fire Extinguishers

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

NO. F&ES/FPW/ **15(2)/442-44/20**
Copy to:-

Dated Guwahati the **12/8/2020**

1. The Deputy Commissioner, **Nagaon**, Assam for information and necessary action.
2. The Commissioner/ Chairman, **Nagaon Municipal Board**, Assam for information and necessary action
3. The Station Officer, **Kaliabor F&ES Station** for information.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2021.**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.
There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/
projection.
7. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2)
No. F&ES/FPW/
To,

F O R M - (G)

Dated Guwahati the _____

The Principal,
Kaliabor College of Education,
Kuwaritol, Nagaon,
Dist:- Nagaon, Assam.

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN **THE KALIABOR COLLEGE OF EDUCATION AT KUWARITOL, NAGAON, DIST:- NAGAON, ASSAM.**

With reference to your completion report under No.

NIL

Dated **10.08.2020** I hereby certify that the building as per description below at
Dag No. **426, 1641** Patta No. - Mouza **Pubthoria, Langichok,**
(Place- **Kuwaritol Nagaon**) has been inspected in respect of implementation of Inbuilt Fire Fighting/
Fire Prevention/ means of escape measures and is declared fit in respect fire safety. The Fire &
Emergency Services, Assam has No objection in its occupation /utilization for the purpose of **COLLEGE**
subject to condition mentioned below.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - **3600 ft²**

2. Purpose of utilization: -

For College Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Manually Operated Electric Fire Alarm system
2. Fire Extinguishers

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

NO. F&ES/FPW/ **15(V) | 442-44 | 20**
Copy to:-

Dated Guwahati the **12/8/2020**

1. The Deputy Commissioner, **Nagaon**, Assam for information and necessary action.
2. The Commissioner/ Chairman, **Nagaon Municipal Board**, Assam for information and necessary action
3. The Station Officer, **Kaliabor F&ES Station** for information.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2021.**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically.
There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/
projection.
7. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati

GOVT. OF ASSAM
OFFICE OF THE DIRECTOR,
FIRE AND EMERGENCY SERVICES, ASSAM, GUWAHATI.



SEE RULE - 18(2)
No. F&ES/FPW/
To,

F O R M - (G)

Dated Guwahati the _____

**The Principal,
Kaliabor College of Education,
Kuwaritol, Nagaon,
Dist:- Nagaon, Assam.**

RENEWAL OF NO OBJECTION CERTIFICATE OF INBUILT FIRE FIGHTING/ FIRE PREVENTION AND MEANS OF ESCAPE MEASURES IN THE KALIABOR COLLEGE OF EDUCATION AT KUWARITOL, NAGAON, DIST:- NAGAON, ASSAM.

With reference to your completion report under No.

NIL

Dated **10.08.2020** I hereby certify that the building as per description below at Dag No. **426, 1641** Patta No. - Mouza **Pubthoria, Langichok,** (Place- **Kuwaritol Nagaon**) has been inspected in respect of implementation of Inbuilt Fire Fighting/ Fire Prevention/ means of escape measures and is declared fit in respect fire safety. The Fire & Emergency Services, Assam has No objection in its occupation /utilization for the purpose of **COLLEGE** subject to condition mentioned below.

DETAILS OF APPROVED OCCUPATION:-

GROUND FLOOR:-

1. Floor area: - **3600 ft²**

2. Purpose of utilization: -
For College Purpose.

Details of inbuilt Fire Fighting and Fire Prevention measures:

1. Manually Operated Electric Fire Alarm system
2. Fire Extinguishers

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

NO. F&ES/FPW/ **15 (12) 442-44 (20)**

Dated Guwahati the **12/8/2020**

Copy to:-

1. The Deputy Commissioner, **Nagaon**, Assam for information and necessary action.
2. The Commissioner/ Chairman, **Nagaon Municipal Board**, Assam for information and necessary action
3. The Station Officer, **Kaliabor F&ES Station** for information.

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati.

CONDITION:-

1. The N.O.C. is valid up to: - **31.03.2021.**
2. There should not be any change of Trade for which this License has been issued.
3. There should not be any structural change in the building either horizontally or vertically. There should not also be any change in the existing arrangements.
4. The Fire Fighting equipments should be in serviceable condition at all time.
5. Water reservoir should always be kept full up to brim.
6. The entrance and exit and the water reservoir should always be free from any obstruction/ projection.
7. **The N.O.C. is liable to be cancelled if the premises (for which the N.O.C. is granted) when inspected are not found conforming to the description and condition under which this N.O.C. is granted.**

S.P. cum F&ES Adviser,
for and on behalf of
Director of Fire and Emergency Services,
Assam, Guwahati